

Table of Contents

Table of Contents	Page 1
Approvals	Page 1
Attention	Page 1
Specification	Page 2
Wiring	Page 3
Dimensions	Page 3



Approvals



CSA Certified: CSA C22.2 No. 24



UL Listed: UL 873

Attention



The installation and maintenance of this product must be done under the supervision of an experienced and trained specialist. Never perform work if gas pressure or power is applied, or in the presence of an open flame.

**Safety
first
O.K.**

On completion of installation on the EMA, perform a function test.



Please read the instruction before installing or operating. Keep the instruction in a safe place. You find the instruction also at www.dungs.com. If these instructions are not heeded, the result may be personal injury or damage to property.

**IFGC CSA
UL ANSI
NFPA**

This product is intended to be used in combination with a control valve to modulate the flow of gas or air.



Any adjustment and application-specific adjustment values must be made in accordance with the equipment manufacturers instructions.

Explanation of symbols


1, 2, 3 ... = Action
• = Instruction

Specification EMA 405 Series


EMA These actuators meet the requirements for damper control or valve control applications where it is desirable to power the crank arm in one direction (CW) to 90 degrees and return it to a normally closed position (CCW) via spring return upon power interruption




EMA 405 & EMA 405-1
Electrical Ratings
 120 VAC (+10 % / -15 %); 60 Hz
Electrical Connection
 1/2" NPT conduit knockout
Power Consumption
 45 VA Running
 45 VA Holding



Enclosure Rating
 NEMA Type 4



Torque
 16 in/lb output




Ambient Temperature
 -40 °F to +136 °F (-40 °C to +58 °C)

Specification EMA 418 Series


EMA These actuators meet the requirements for damper control or valve control applications where it is desirable to power the crank arm in one direction (CW) to 90 degrees and return it to a normally closed position (CCW) via spring return upon power interruption




EMA 418 & EMA 418-2
Electrical Ratings
 120 VAC (+10 % / -15 %); 60 Hz
Electrical Connection
 1/2" NPT conduit knockout
Power Consumption
 120 VA Running
 42 VA Holding



Enclosure Rating
 NEMA Type 4



Torque
 60 in/lb output



Ambient Temperature
 -40 °F to +136 °F (-40 °C to +58 °C)


Model No.	Order No.	Travel	Opening time no load	Opening time full load	Torque (in.- lbs.)	Weight Lbs. (actual/shipping)
EMA-405	43117	180°	20 s	60 s	16	8
EMA-405-1	43117-1	90°	10 s	60 s	16	8
EMA-418	43199	180°	20 s	60 s	60	8
EMA-418-2	43199-1	90°	10 s	30 s	60	8

Wiring


- 1) Inspect unit before installing, look for broken parts or leaks.
- 2) Disconnect all power to the actuator before wiring to prevent electrical shock and equipment damage.
- 3) Do not exceed the electrical ratings given in the specifications and on the actuator.
- 4) Attach a flexible 1/2" NPT conduit to the actuator. Use NEMA Type 4 compatible type connectors.
- 5) Connect the wiring to the appropriate terminals.



All wiring must comply with local electrical codes, ordinances and regulations.



Dimensions



We reserve the right to make modifications in the course of technical development.



Karl Dungs Inc.
 3890 Pheasant Ridge Drive NE
 Suite 150
 Blaine, MN 55449, U.S.A.
 Phone 763 582-1700
 Fax 763 582-1799
 e-mail info@karldungsusa.com
 Internet <http://www.dungs.com/usa/>

Karl Dungs GmbH & Co. KG
 P.O. Box 12 29
 D-73602 Schorndorf, Germany
 Phone +49 (0)7181-804-0
 Fax +49 (0)7181-804-166
 e-mail info@dungs.com
 Internet <http://www.dungs.com>